

Intelligent Temperature Controller User Manual




Features

- Optional input signal types.
- PID arithmetic and with auto-tuning function.
- Different control types (please refer OT parameters).
- RUN/STOP function can be switch.

The instruction explain instrument settings, connections, name and etc, please read carefully before you use the temperature controller.

■ Model Illustration



■ Order Information


No.	Model	Control output	Alarm
1	AI108-4/6/7/9-SB10-□	SSR	1
2	AI108-4/6/7/9-RB10-□	RELAY	1

NOTE: T: TC input, including K/J/E/T; R: RTD input, including PT100/CU100/CU50

■ Specification

Sample rate	2 times/second
Relay capacity	AC 250V /3A life of rated load>100,000 times
Power supply	AC/DC 100 ~ 240V (85-265V)
Power consumption	< 6VA
Environment	Temperature of indoor: 0 ~ 50°C no condensation; Humidity: < 85%RH, altitude<2000m
Storage environment	-10 ~ 60°C, no condensation
SSR output	DC 24V pulse voltage, load<30mA
Insulation impedance	input, output, power VS meter cover > 20MΩ
ESD	IEC/EN61000-4-2 Contact ±4KV /Air ±8KV perf.Criteria B
Pulse train anti-interference	IEC/EN61000-4-4 ±2KV perf.Criteria B
Surge immunity	IEC/EN61000-4-5 ±2KV perf.Criteria B
Voltage drop & Short interruption immunity	IEC/EN61000-4-29 0% ~ 70% perf.Criteria B
Dielectric strength	Signal input & output & power 1500VAC 1min, below 60V low voltage DC500V, 1min
Total weight	About 400g
Shell material	The shell and panel frame PC/ABS (Flame class UL94V-0)
Panel material	PET(F150/F200)
Power failure memory	10 years, times of writing: 1 million times
Panel protection level	IP65(IEC60529)
Safety standard	IEC61010-1 overvoltage category II, pollution level 2, level II (Enhanced insulation)

2. Isolation diagram:




"//": Isolation

3. Specification of measuring signal table:


Input		Symbol	Measure range	Resolution	Accuracy	Input impedance/ auxilia current
TC	K		-50 ~ 400	1°C	0.5%F.S±3digits	> 500kΩ
	J		0 ~ 400	1°C	0.5%F.S±3digits	> 500kΩ
	E		0 ~ 400	1°C	0.5%F.S±3digits	> 500kΩ
	T		-50 ~ 400	1°C	0.5%F.S±2°C	> 500kΩ
RTD	PT100		-199 ~ 400	1°C	0.5%F.S±3digits	0.2mA
	CU50		-50 ~ 150	1°C	0.5%F.S±3°C	0.2mA
	CU100		-50 ~ 150	1°C	0.5%F.S±1°C	0.2mA

■ Panel Illustration



No	Symbol	Name	Function
1	OUT1	OUT1 light(red)	Host control output indicator light,it light when the output is ON
	OUT2	OUT2 light(red)	Cooling output indicator light,it light when the output is ON
	AL1	Alarm1# light(red)	1st loop alarm output indicator light,alarm output with light,no alarm output without light.
	AL2	Alarm2# light(red)	2nd loop alarm output indicator light,alarm output with light,no alarm output without light.
	AT	AT light(green)	Auto-tuning indicator light,it show setting state when it light
2	SET	SET function key	Menu key/ensure key,to use enter or back to modified mode or ensure/save parameters
3	◀ AT	Shift/AT key	Activation key/shift key/AT setting key,long press to enter or back to auto-tuning under the measure control mode.
4	▲ R/S	Add key/R/S	Add key,long press it can reach switch of RUN/STOP mode under the measure control mode.
5	▼	Reduce key	Reduce key
6	SV	Display window(green)	Setting value/parameters display window,display "STP" =stop control
7	PV	Display window(red)	measured value/parameters code display window

■ Dimensions




Model	A	B	C	D	E	F	G	H(Min)	J	K(Min)
4:(48*48)	48	48	97.5	6.5	91	45	45.5	25	45.5	25
6:(96*48)	48	96	97.5	9	88.5	89.5	45	25	92	25
7:(72*72)	72	72	97.5	9	88.5	67	67.5	25	67.5	25
9:(96*96)	96	96	97.5	9	88.5	91.5	92	25	92	25

■ Operation & Menu

1. Operation process of Factory default (PID heating):

Measure control mode



NOTE:The meter will hide unrelated parameters according to operation way of OT parameter.
We suggest to set the OT parameters before using the meter in the first time.

Parameters will keep display all the time for all the model and all the setting.

Parameters will be hided based on model and menu setting.

2. Menu Illustration

No.	symbol	Name	Description	Set range	Factory default
1		AL1	1st alarm value.(Note:the minus is dealed as absolute value when it is as a deviation value)	Signal set range	10
2		HY1	1st alarm backlash value	0 ~ 100	1
3		AD1	1st alarm mode.(Note:it should be set 0 when 1st alarm is as OUT2,and close the alarm function.)	0 ~ 6	3
4		PS	Translation correction value,display value=actual measured value+translation correction value	-199 ~ 999	0
5		INP	Optional input measured signal type		K
6		OT	Control type: 0: ON/OFF control, related parameter: DB ; 1: PID heating,related parameters:P,I,D,OVS,CP,ST; 2: No definition 3: PID heating & cooling(Cooling control OUT2 output by AL1 relay),related parameters:P,I,D,OVS,DB,CP,CP1,PC,ST; 4: Excess temperature cooling control type,related parameter:DB	0 ~ 4	1
7		P	Proportional band,the lower of setting value,the faster of system heating or the more slowly.Increasing proportional band can reduce vibration,but it will add the control bias vibration.Reducing proportional band can reduce control bias,but it will lead to vibration	0 ~ 999	30
8		I	The lower of integral time value,the stronger of integral action,the more tendency to eliminate and deviation of a set value.If integral action is week,it maybe can not eliminate the deviation. Unit:S	0 ~ 999	120
9		D	Differential time,reduce the effect of differential time to a proper value,which can prevent the system oscillation.The higher value,the stronger function of differential. Unit:s	0 ~ 999	30
10		OVS	Overshoot limit,in the process of PID control,when PV>SV+OVS,it force off output;The lower value,the lower PID adjusted range,the worse control stability;please set a proper value according actual state.	0 ~ 999	5
11		DB	Bit control backlash(nagetive backlash bit control)or cooling control and compressor cooling control dead zone. please change the value according to decimal position, when you change INP type.	0 ~ 100	5
12		CP	OUT1 control cycle,1:SSR control output,4-200:relay control output.Unit:s	1 ~ 200	20
13		CP1	OUT2 control cycle,cooling relay output cycle.Unit:s	4 ~ 200	20
14		PC	OUT2 cooling proportionality coefficient,the higher of value,the stronger of cooling	1 ~ 100	10
15		LCK	Lock function. 001:SV value can not be modified;010:menu setting value only can be checked ,cannot modified; 033: can enter to advanced menu; 123: menus reset to factory setting.	0 ~ 999	0

3.Advanced Menu Illustration

16	ACT	ACT	Control execution type,0:relay/SSR output; 1:single SSR output control	0 ~ 1	0
17	ST	ST	power on auto-tuning switch . 0: normal control after power on 1: enter PID auto-tuning status after power on . Long press «AT key to exit the auto-tuning	0 ~ 1	0
18	AE1	AE1	1st alarm extensions (refer to alarm extend function table page 6)	0 ~ 5	0
19	FT	FT	PV filter coefficient of digital filter,the higher of value,the stronger of filter function	0~255	10
20	UT	UT	Temperature unit	°C, °F	°C
21	DTR	DTR	PV fuzzy tracking value,it can get a stable control display value in some status. Note:when the alarm setting value is equal with SV setting value after setting the DTR value,operation of alarm output is subject to actual measured value.	0.0~2.0	1.0
22	VER	VER	Display equipped with software version	can not be modified	--

■ Key function operation

1.PID Parameter identification and auto-tuning operation:

- 1) The factory default PID parameters usually does not apply to use occasion;please using auto-tuning function to get a suitable PID parameter.
- 2) The meter will enter control output since the power input, now,you can set the monitoring mode to avoid to affect the effect of auto-tuning function,or switch off the power of control output load.No matter how to operate, it should guarantee the set value greater than the current measured value and drop the bigger the better.
- 3) Before auto-tuning, set the proper alarm value,or remove the alarm effect to avoid the effect of alarm output.
- 4) Set SV value.
- 5) OT parameter set to 1 (PID control)
- 6) Under the condition of PV value at normal room temperature,please back to monitoring mode or input the load power,and long press “ « AT ” enter auto-tuning mode,now,AT indicator will shine.
- 7) Auto-tuning need a period, to ensure the auto-tuning result,please don't modify parameters or power-off during auto tuning.
- 8) When AT light is off , it will exit the auto-tuning. PID will update automatically, and can get good control result.
- 9) During auto-tuning, long press “ « AT ” key, measure beyond the range,display abnormally, shift to “STOP” status,power-off will stop the auto -tuning.
- 10) You can set a proper PID parameter with your rich experience.





2. PID heating & Cooling control operation

- 1) Set the control mode OT to 3.
- 2) PID heating control act on OUT1; Cooling control act on OUT2.
- 3) Cooling control OUT2 will make output by AL1 alarm relay.
- 4) Please set the cooling start offset to a value larger than 5 , to ensure the cooling would not affect PID heating control impact.
- 5) Please set the cooling control cycle CP1 to a proper value, and change the cooling scaling factor to a a proper value.
- 6) When PV value > SV+DB value,the cooling control start to effect;the bigger value of PV,the longer output time of OUT2

■ Alarm function diagram

1.Alarm parameters and output logic diagram

Symbol description : “★” means alarm hysteresis , “▲” means alarm value , “△” means SV value

No.	Alarm type	Alarm output(AL1、AL2 is independent of each other) Image:the hatched section means the alarm action
1	High limit absolute value alarm	
2	Low limit absolute value alarm	
3	※High limit deviation value alarm	
4	※Low limit deviation value alarm	
5	※High/low limit deviation value alarm	
6	※High/low limit interval value alarm	


※When the alarm value with deviation alarm set to a negative number,it will deal with it as an absolute value.

2.Alarm extension function table


AE1/AE2 value	Alarm handling mode when show HHH/LLL	Remark
0	The state when alarm keep HHH/LLL in previous time	As long as meet the requirement of alarm,alarm output
1	Forced alarm output	
2	Forced alarm close	Before the PV value reach the set value in the first time,the alarm does not output.
3	The state when alarm keep HHH/LLL in previous time	
4	Forced alarm output	
5	Forced alarm close	

■ Connection


AI108-4




AI108-6



AI108-7



AI108-9



Note: Please subject to the connection on meter if any difference here

■ Methods of simple fault

Display	Methods
LLL/HHH	Checks whether the input disconnection and whether normal of FH value,FL value,working environment temperature and whether input signal is selected correctly.